

**Project Information** 

**Department of Community Development** 801 228th Avenue SE Sammamish, WA 98075-9509 Phone: 425-295-0500

Fax:

425-295-0600

Web: www.sammamish.us www.mybuildingpermit.com

SMC 16.05.153

## Electrical Permit Checklist for Residential Solar Photovoltaic Systems

Contractors must complete and submit this checklist, a roof layout of solar panels and a one-line diagram online at MyBuildingPermit.com or in person at City Hall.

Project Address:	Parcel Number(s):			
Property Owner:	Owner Phone:			
Contractor Name:	Contractor License No.:			
Contractor Phone:				
Describe PV system, including manufacturer and model r	number of major equipment:			
Floatrical Domest Cubustitle Obsaldist				
Electrical Permit Submittal Checklist				
		Yes	No	N/A
PV modules, inverters, and combiner boxes are identified	-			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4]	L 1741 and are listed for utility		_	N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service.	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)]			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] Cities Electrical Code			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements For Split-Bus modules, the AC interconnection is one of the	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] Cities Electrical Code			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] Cities Electrical Code ne six service disconnects.			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements For Split-Bus modules, the AC interconnection is one of the Is the system grounded or ungrounded?	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] Cities Electrical Code ne six service disconnects. erly labeled?			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements For Split-Bus modules, the AC interconnection is one of the Is the system grounded or ungrounded? Has DC Ground-Fault Protection been provided and properlist the PV disconnect permanently marked and installed in Are PV source or output circuits on or inside a building in	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] Cities Electrical Code ne six service disconnects. erly labeled? n a readily accessible location?			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements For Split-Bus modules, the AC interconnection is one of the Is the system grounded or ungrounded? Has DC Ground-Fault Protection been provided and properly the PV disconnect permanently marked and installed in Are PV source or output circuits on or inside a building in Has the system been grounded at one single point?	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] cities Electrical Code ne six service disconnects. erly labeled? n a readily accessible location? a metal raceway and marked?			N/A
PV modules, inverters, and combiner boxes are identified. The inverters are listed and labeled in accordance with U interaction. [WAC 51-51 M2302.4] The AC interconnection point is on the load side of service. The system meets all current NEC, City and Washington C requirements For Split-Bus modules, the AC interconnection is one of the Is the system grounded or ungrounded? Has DC Ground-Fault Protection been provided and properlist the PV disconnect permanently marked and installed in Are PV source or output circuits on or inside a building in	L 1741 and are listed for utility e disconnect. [NEC 705.12(B)] cities Electrical Code ne six service disconnects. erly labeled? n a readily accessible location? a metal raceway and marked?			N/A

Maximum load added to the panelboard is based on the rating of the panelboards bus/main OCPD combination. Maximum inverter OCPD may be no greater than 120% of the panelboard bus rating minus the panelboard main

OCPD rating in accordance with NEC 705.12(D)(2)(3)(b) Acceptable combinations include (check combination that applies): 100 amp bus/100 amp main OCPD - 3,840 watts, maximum 20 amp inverter OCPD. 125 amp bus/100 amp main OCPD - 9,600 watts, maximum 50 amp inverter OCPD. 125 amp bus/125 amp main OCPD - 4,800 watts, maximum 25 amp inverter OCPD. 150 amp bus/150 amp main OCPD - 5,760 watts, maximum 30 amp inverter OCPD. 200 amp bus/200 amp main OCPD - 7,860 watts, maximum 40 amp inverter OCPD. 225 amp bus/225 amp main OCPD - 8,640 watts, maximum 45 amp inverter OCPD. 225 amp bus/200 amp main OCPD - 13,440 watts, maximum 70 amp inverter OCPD. Other - Electrical Permit with Plan Review Required Note 1: Listed un-altered factory main/bus combination. Alteration of the panelboard main OCPD will require plan review. Note 2: The circuit conductors and overcurrent devices shall be sized to carry not less than 125 percent of the maximum currents as calculated in 690.8(A). The rating or setting of overcurrent devices shall be permitted in accordance with 240.4(B) and (C). NEC 690.8(B)(1) Note 3: If a panelboard employs a snap switch rated 30 amperes or less in any branch circuit, it cannot be rated more than 200 amperes unless there is a supply side overcurrent protection at 200 amperes or less within the panelboard. This requirement does not apply to panelboards equipped with circuit breakers. Section 408.36(A) of the NEC. I have attached an Electrical One-Line Diagram that includes: Wire sizes ☐ Metering Overcurrent devices and sizing Grounding electrode Conduit Sizes Disconnect co-located with conductors production meter Comments:

## Electrical Permit Manufacturer's Specification Sheet Requirements

Provide manufacturer's specification sheet for all components but not limited to:

- 1. Modules
- 2. Inverter
- 3. Microinverter
- 4. Power Optimizers
- 5. Any Alternate Power Sources
- 6. Mounting/racking systems

All required markings and labels are provided

A diagram of the roof layout of all panels, modules, clear access pathways and approximate locations of electrical disconnecting means and roof access points.

building Permit Exemption Checklist		
PV system is designed and proposed for a detached one- or two-family dwelling or townhouse not more than three stories above grade or detached accessory structure that is code compliant to setbacks and height, or code allows expansion of nonconformity for solar modules.	Yes	No
Modules installed do not exceed the highest point of the roof.		
Specify roof pitch (rise/run):		
Rooftop is made from lightweight material such as a single layer of composition shingles, metal roofing, lightweight masonry, or cedar shingles.		
The installation will comply with the manufacturer's instructions.		
The installation will meet the requirements of NFPA 70 National Electric Code, and all required electrical permit(s) must be obtained from the Authority Having Jurisdiction to administer the electrical code.		
The installation will meet the requirements of the International Fire Code as amended by WA State. If yes, indicate which option will be used to meet the IFC access regulations:		
☐ The dwelling will be sprinklered, so no access pathways are required The total array does not exceed 33% of the total roof area and does not exceed 1,000 sq. ft. in total area and 18" minimum unobstructed pathways will be provided along each side of all horizontal ridges		
<ul> <li>Pathways meeting IFC Sections 605.11.3.2.1 through 605.11.3.2.4 are to be provided</li> </ul>		
The PV system is designed for the wind speed of the local area, and will be installed per the manufacturer's specifications		
The ground snow load does not exceed 70 pounds per square foot.		
Total dead load of modules, supports, mountings, raceways and all other appurtenances weigh no more than four pounds per square foot.		
Enter total dead load of system (psf):		
To address uplift, modules are mounted no higher than 18" above the surface of the roofing to which they are affixed.		
Supports for solar modules are installed to spread the dead load across as many roof-framing members as needed to ensure that no point load exceeds fifty (50)pounds.		
The photovoltaic modules and supporting structure will be constructed of noncombustible materials or fire-retardant treated wood equivalent to that required for the roof construction.		
Roof and wall penetrations will be construction. flashed and sealed to prevent entry of water, rodent, and insects.		

PV modules are listed and labeled with a fire classification in accordance with UL 1703 M2302.2.3]	3. [IRC		
If you answered yes to all of the above questions in Section 3, your project does not requ Electrical permit is still required.	ire a buildin	g permit	:. An
Acknowledgements			
As the property owner or authorized representative of the above listed property, I attest this checklist is accurate to the best of my knowledge. Inaccurate information may result remove the installation.			
Owner/Agent Name Printed:			
Owner/Agent Signature:	Date:		